

Your Project #: ST. GABRIEL
Your C.O.C. #: NA

Attention: Kim Dalgarno
Halton Catholic District School
802 Drury Lane
Burlington, ON
L7R 4L3

Report Date: 2007/08/21

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A786690
Received: 2007/08/15, 10:02

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2007/08/20	2007/08/20	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

SEAN CONACHER,
Email: Sean.Conacher@maxxamanalytics.com
Phone# (905) 817-5700 Ext:5767

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A786690
Report Date: 2007/08/21

Halton Catholic District School
Client Project #: ST. GABRIEL
Project name:
Sampler Initials:

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			U07004	U07005		
Sampling Date			2007/08/14 06:10	2007/08/14 06:45		
COC Number			NA	NA		
	Units	Criteria	ST.	ST.	RDL	QC Batch
			GABRIEL-STANDING	GABRIEL-FLUSHED.		

METALS						
. Lead (Pb)	ug/L	10	9.9	3.5	0.5	1336049

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA:

Maxxam Job #: A786690
Report Date: 2007/08/21

Halton Catholic District School
Client Project #: ST. GABRIEL
Project name:
Sampler Initials:

GENERAL COMMENTS

Results relate only to the items tested.

Halton Catholic District School
Attention: Kim Dalgarno
Client Project #: ST. GABRIEL
P.O. #:
Project name:

Quality Assurance Report
Maxxam Job Number: MA786690


QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1336049 MIL	MATRIX SPIKE	. Lead (Pb)	2007/08/20		104	%	80 - 120
	Spiked Blank	. Lead (Pb)	2007/08/20		100	%	85 - 115
	Method Blank	. Lead (Pb)	2007/08/20	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2007/08/20	NC		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A786690

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



BRAD NEWMAN, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.