

Your Project #: ST. MATHEW
Site: OAKVILLE, ON
Your C.O.C. #: N/A

Attention: Kim Dalgarno
Halton Catholic District School
802 Drury Lane
Burlington, ON
L7R 4L3

Report Date: 2007/08/22

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A787316
Received: 2007/08/16, 09:24

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2007/08/21	2007/08/21	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

SEAN CONACHER,
Email: Sean.Conacher@maxxamanalytics.com
Phone# (905) 817-5700 Ext:5767

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A787316
Report Date: 2007/08/22

Halton Catholic District School
Client Project #: ST. MATHEW
Project name: OAKVILLE, ON
Sampler Initials:

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			U09440	U09441	U09441		
Sampling Date			2007/08/15 04:45	2007/08/15 05:20	2007/08/15 05:20		
COC Number			N/A	N/A	N/A		
	Units	Criteria	ST. MATTHEW STANDING	ST. MATTHEW FLUSHED	ST. MATTHEW FLUSHED Lab-Dup	RDL	QC Batch

METALS							
. Lead (Pb)	ug/L	10	26 (1)	8.3	8.3	0.5	1336936

N/A = Not Applicable
RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA:
(1) POTENTIAL EXCEEDENCE FOR PARAMETER

Maxxam Job #: A787316
Report Date: 2007/08/22

Halton Catholic District School
Client Project #: ST. MATHEW
Project name: OAKVILLE, ON
Sampler Initials:

GENERAL COMMENTS

Results relate only to the items tested.

Halton Catholic District School
Attention: Kim Dalgarno
Client Project #: ST. MATHEW
P.O. #:
Project name: OAKVILLE, ON

Quality Assurance Report
Maxxam Job Number: MA787316

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1336936 JBW	MATRIX SPIKE						
	[U09441-01]	. Lead (Pb)	2007/08/21		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2007/08/21		97	%	85 - 115
	Method Blank	. Lead (Pb)	2007/08/21	ND, RDL=0.5		ug/L	
	RPD [U09441-01]	. Lead (Pb)	2007/08/21	1.1		%	25

ND = Not detected
RPD = Relative Percent Difference
SPIKE = Fortified sample

Notification Log

Maxxam Job #: A787316
Report Date: 2007/08/22


Halton Catholic District School
PROJECT #: ST. MATHEW
Site: OAKVILLE, ON

Sample	Client Sample ID	Parameter	Reg.	Result	Units	M.A.C. Limit	Agency Contacted	Date Contacted
J09440-01	ST. MATTHEW STANDING	Lead (Pb)	243	26	ug/L	10	MOH	2007/08/22
J09440-01	ST. MATTHEW STANDING	Lead (Pb)	243	26	ug/L	10	SPILLS	2007/08/22
J09440-01	ST. MATTHEW STANDING	Lead (Pb)	243	26	ug/L	10	WWO	2007/08/22

Validation Signature Page

Maxxam Job #: A787316

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



BRAD NEWMAN, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.