

Your Project #: ST. MICHAEL
Site: OAKVILLE, ON
Your C.O.C. #: N/A

Attention: Kim Dalgarno
Halton Catholic District School
802 Drury Lane
Burlington, ON
L7R 4L3

Report Date: 2007/08/22

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A787310
Received: 2007/08/16, 09:24

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2007/08/21	2007/08/21	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

SEAN CONACHER,
Email: Sean.Conacher@maxxamanalytics.com
Phone# (905) 817-5700 Ext:5767

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A787310
Report Date: 2007/08/22

Halton Catholic District School
Client Project #: ST. MICHAEL
Project name: OAKVILLE, ON
Sampler Initials:

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			U09402	U09403		
Sampling Date			2007/08/15 06:00	2007/08/15 06:35		
COC Number			N/A	N/A		
	Units	Criteria	ST. MICHAEL STANDING	ST. MICHAEL FLUSHED	RDL	QC Batch

METALS						
. Lead (Pb)	ug/L	10	2.3	0.6	0.5	1336936

N/A = Not Applicable
RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA:

Maxxam Job #: A787310
Report Date: 2007/08/22

Halton Catholic District School
Client Project #: ST. MICHAEL
Project name: OAKVILLE, ON
Sampler Initials:

GENERAL COMMENTS

Results relate only to the items tested.

Halton Catholic District School
 Attention: Kim Dalgarno
 Client Project #: ST. MICHAEL
 P.O. #:
 Project name: OAKVILLE, ON

Quality Assurance Report
 Maxxam Job Number: MA787310


QA/QC Batch			Date Analyzed					
Num Init	QC Type	Parameter	yyyy/mm/dd	Value	Recovery	Units	QC Limits	
1336936	JBW	MATRIX SPIKE	. Lead (Pb)	2007/08/21		99	%	80 - 120
		Spiked Blank	. Lead (Pb)	2007/08/21		97	%	85 - 115
		Method Blank	. Lead (Pb)	2007/08/21	ND, RDL=0.5		ug/L	
		RPD	. Lead (Pb)	2007/08/21	1.1		%	25

ND = Not detected
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A787310

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



BRAD NEWMAN, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.